CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



CAL FIRE SINCE 1895

LISTING No. 7170-1657:187 Page 1 of 2

CATEGORY: Control Unit (High-Rise)

LISTEE: GE Security, Inc., 8985 Town Center Parkway, Bradenton, FL 34202

Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

DESIGN: Models EST3, EST3R, EST3-230, EST3R-230, EST200, EST200R, EST200-2 and

EST200R-2 fire alarm control units. Power limited. Automatic, manual, coded, noncoded, local, auxiliary, remote station, (DACT),(reverse polarity), proprietary (multiplex), central station, waterflow and sprinkler supervisory service. Model EST3 is also suitable for smoke control. Refer to listee's data sheet for additional detailed product description and

operational considerations. System components:

3-BPS/M, 3-BPS/M/230 Booster Power Supply 3-PPS/M, 3-PPS/M-230 Primary Power Supply

3-BBC/M, 3-BBC/M-230 Battery Booster Charger Power Supply

3-RS232 CPU RS232 Comm
3-XMEM CPU Memory Option

3-IDC8/4 Zone Card

3-CPU, 3-CPU1, 3-CPU2, 3-CPU3
Central Processing Unit CPU LCD Display

3-OPS Off Premises Signaling Module

3-LDSM
3-LRMF
Blank LRM Filler
3-CHAS4, -CHAS-5, -CHAS-7
Module Chassis
3-CAB-5(R),-7(R),-14(R),-21(R)
Module Cabinet (red)

3-TAMP, 3-TAMP5

3-RCC7(R),-RCC14(R),-RCC21(R)

Tamper Switch
Closet Cabinet (red)

3-PSMON
3-BPMON
3-BPMON
3-BBCMON
Power Supply Drive Monitor
Power Supply Booster Monitor
Battery Booster Charger Monitor

3-24G,-24Y,-12RY,-12SY,-12SR,-12SG LED Display 3-12/RY,-12/2Y,-12/S1GY LED Display LED Display 3-12/S1RY,-18S1G2Y,-6/3S1G2Y LED Display LE

3-CAB5BR Enclosure

3-SSDC, 3-SSDC1, 3-SDDC1 Single Loop Controller Module Signature Data Card

3-ASU, 3-ASUMX/100
3-FTCU
3-ASU/FT

Signature Data Card
Audio Source Module
Firefighter Phone Module
Audio/Firefighter Module

3-ZA30, 3-ZA15 Amplifier

3-RS485(130316/130410-01)
3-RS485A, 3-RS485B, 3-RS485R
Network Communication Card
Network Communication Card
Dual Loop Controller Module

3-FIB, 3-FIBA Fiber/Copper Data Com Module 3-FIBMB Fiber Optic Interface Card

Listing No. 7170-1657:187 Page 2 of 2

CDR-3 Coded Output Module

3-AADC, 3-AADC1 Analog Addressable Communication Module

3-ATPINT ATPC Interface Module
3-REMICA, 3-REMICP Remote Microphone
PT1-S System Printer
PT1-P System Printer Parallel

3-ZA90, 3-ZA20A, 3-ZA20B Zone Amplifiers 3-ZA-40A, 3-ZA40B, 3-ZA95 Zone Amplifiers

ATCK Attack Kit Cover for 3-RCC7R cabinet 3-MODCOM, 3-MODCOMP Modem communicator/pager interface

3-NSHM1, 3-NSHM2 Modem Communication Cards
3-SAC Security Access Control Module
3-ASUXM/100 Audio and Telephone Masters

RATING: EST3, EST3R, EST200, EST200-2, EST200R, EST200R-2: 120 VAC

EST3-230, EST3R-230: 220 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units suitable for high-rise applications when used in

conjunction with separately listed electrically and functionally compatible initiating and indicating devices. Model EST is also suitable for smoke control. Refer to listee's

Installation Instructions Manual for details.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE: 1. For <u>Fire Alarm Verification Feature</u> (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

2. Formerly 7170-1591:187 and 7170-1388:212

08-17-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 9, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division